



KERALA WATER AUTHORITY

QUALITY CONTROL DISTRICT LABORATORY

VELLAYAMBALAM, THIRUVANANTHAPURAM

Telephone No - 0471-2735303, E-mail - aeequalitytvm@gmail.com

TEST REPORT

Test Report No: 2024/QCDL/TVM/3841

Date: 01.08.2024

Customer Name & Address : NAVAJEEVAN BETHANY VIDHYALAYA
BETHANY HILLS, NALANCHIRA P O, TVPM.
Phone Number : 8281496795

Date of collection: 27.07.2024	Sampling was done by: The Customer (QUA_153924)
Sample code: 2024/QCDL/TVM/3841	Sample particulars: Drinking Water
Sample quantity: 250 ml	Date of analysis: From: 27.07.2024 To: 28.07.2024

Sl. No	Parameters	Acceptable limits as per-IS 10500-2012	Test Method	Result
1	Total Coliforms	Shall not be detected / 100ml	IS 15185: 2016 ISO 9308 - 1:2014	ABSENT
2	E. Coli	Shall not be detected / 100ml	IS 15185: 2016 ISO 9308 - 1:2014	ABSENT

Remarks:

1. The results stated above related only to the sample received for testing
2. This test report shall not be reproduced except in full without the written approval of the laboratory management.
3. The retention period of the sample is seven days from the date of analysis.

Analyzed by

BACTERIOLOGIST
QUALITY CONTROL DISTRICT LAB
KERALA WATER AUTHORITY
THIRUVANANTHAPURAM
Authorized Signatory

End of the report

QCDL/TR/D/7.8/A	Issue No: 3	Issue Date: 26.10.2023
Rev. No: 02	Rev. Date: 17.05.2023	Page 1 of 1



Principal
NAVAJEEVAN BETHANY VIDHYALAYA (CBSE)
BETHANY JUNCTION, NALANCHIRA
THIRUVANANTHAPURAM - 15



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LABORATORY

Vellayambalam, Thiruvananthapuram – 695033
Tel: 04712735303; e-mail: aeequalitytvp@gmail.com



TC-12164

TEST REPORT

ULR No: TC1216424000002708F

Test Report No: 2024/QCDL/TVM/3841

Date: 01.08.2024

Customer Name & Address : NAVAJEEVAN BETHANY VIDHYALAYA BETHANY HILLS, NALANCHIRA P O, TVPM. Phone Number : 8281496795	
Date of collection: 27.07.2024	Sampling was done by: The Customer (QUA_153924)
Sample code: 2024/QCDL/TVM/3841	Sample particulars: Drinking Water
Sample quantity: 2 litre	Date of analysis: From: 29.07.2024 To: 31.07.2024

Sl. No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Chloride (as Cl)	mg/l	IS 3025 (Part 32), Argentometric Method	250	12
2	Electrical Conductivity	micro mhos/cm	IS 3025 (Part 14)	-	62.18
3	Iron	mg/l	IS 3025 (Part 53), 1,10 Phenanthroline Method	1.0	BDL (DL=0.075)
4	Nitrate	mg/l	APHA 24th Edition 4500-NO ₃ -B, UV Spectrophotometric Screening Method	45	1.67
5	pH		IS 3025 (Part 11), Electrometric Method	6.5 to 8.5	6.86
6	Total Hardness (as CaCO ₃)	mg/l	IS 3025 (Part 21), EDTA Method	200	19.4
7	Turbidity	NTU	IS 3025 (Part 10), Nephelometric Method	1	0.15

BDL=Below Detection Limit; DL=Detection Limit

Remarks:

1. The results stated above related only to the sample received for testing
2. This test report shall not be reproduced except in full without the written approval of the laboratory management.
3. The retention period of the sample is seven days from the date of analysis.

[Signature]

Analyzed by

End of the report

QCDL/TR/D/7.8/A	Issue No: 3	Issue Date: 26.10.2023
Rev. No: 02	Rev. Date: 17.05.2023	Page 1 of 1

[Signature]
SEENA H
Authorized Signatory

PRINCIPAL
NAVAJEEVAN BETHANY VIDHYALAYA (CBSE)
BETHANY JUNCTION, NALANCHIRA
THIRUVANANTHAPURAM - 695033



[Signature]
PRINCIPAL
NAVAJEEVAN BETHANY VIDHYALAYA (CBSE)
BETHANY JUNCTION, NALANCHIRA
THIRUVANANTHAPURAM - 695033



തിരുവനന്തപുരം മുനിസിപ്പൽ കോർപ്പറേഷൻ

പിൻകോഡ്-695033 ജി. എസ്. റ്റി- 32AAAGT0076LIZ9

ഫോൺ നമ്പർ 0471 2320821 ഇമെയിൽ : tvpmcorpn@gmail.com

<https://tmc.lsgkerala.gov.in>

ZKPK/A6/111068/2025

തീയതി: 10/03/2025

SANITARY CERTIFICATE

NAVAJEEVAN BETHANY VIDHYALAYA BETHANY HILLS, NALANCHIRA P. O. T. V M.P Certified that sanitary arrangements inside and premises of the school are found satisfactory the classrooms and staff room have proper and adequate ventilation and safe drinking water facility, the water taps urinals and latrines are sufficient according to the school strength. Also certify that anti-tobacco boards have seen displayed as per COTPA-2013

10/3/25
CLEAN CITY MANAGER

സി.അജയകുമാർ
ക്ലിൻ സിറ്റി മാനേജർ
(പൊതുജനാരോഗ്യ വിഭാഗം)
സോൺ-II
മുനിസിപ്പൽ കോർപ്പറേഷൻ
തിരുവനന്തപുരം



10/06/2025
PRINCIPAL

NAVAJEEVAN BETHANY VIDYALAYA (CBSE)
BETHANY JUNCTION, NALANCHIRA
THIRUVANANTHAPURAM - 15